

# Missouri Department of Natural Resources



## PUBLIC NOTICE

### APPLICATION FOR MISSOURI STATE OPERATING PERMIT

DATE: **July 16, 2004**

In accordance with the state Clean Water Law, Chapter 644, RSMo, Clean Water Commission regulation 10 CSR 20-6.010, and the federal Clean Water Act, the applicants listed herein have applied for authorization to either discharge to waters of the state or to operate a no-discharge wastewater treatment facility. The proposed permits for these operations are consistent with applicable water quality standards, effluent standards and/or treatment requirements or suitable timetables to meet these requirements (see 10 CSR 20-7.015 and 7.031). All permits will be issued for a period of five years, unless noted otherwise in the Public Notice for that discharge.

On the basis of preliminary staff review and the application of applicable standards and regulations, the Missouri Department of Natural Resources (MDNR), as administrative agent for the Missouri Clean Water Commission, proposes to issue a permit(s) subject to certain effluent limitations, schedules, and special conditions. The proposed determinations are tentative pending public comment.

Persons wishing to comment on the proposed permit conditions are invited to submit them in writing to the **Department of Natural Resources, St. Louis Regional Office, 7545 South Lindbergh, Suite 210, St. Louis, Missouri 63125, ATTN: Thomas M. Siegel, Chief, Permits and Engineering**. Please include the permit number in all comment letters.

Comments should be confined to the issues relating to the proposed action and permit(s) and the effect on water quality. The MDNR may not consider as relevant comments or objections to a permit based on issues outside the authority of the Clean Water Commission, (see Curdt v. Mo. Clean Water Commission, 586 S.W.2d 58 Mo. App. 1979).

**All comments must be postmarked by August 15, 2004 or received in our office by 5:00 p.m. on August 18, 2004.** The requirement of a signed document makes it impossible to accept email comments for consideration at this time. Comments will be considered in the formulation of all final determinations regarding the applications. If response to this notice indicates significant public interest, a public meeting or hearing may be held after due notice for the purpose of receiving public comment on the proposed permit or determination. Public hearings and/or issuance of the permit will be conducted or processed according to 10 CSR 20-6.020.

Copies of all draft permits and other information including copies of applicable regulations are available for inspection and copying at DNR's website, <http://www.dnr.state.mo.us/wpscd/wpcp/homewpcp.htm>, or at the Department of Natural Resources, St. Louis Regional Office, 7545 S. Lindbergh, Suite 210, St. Louis, Missouri 63125, between the hours of 8:00 a.m. and 5:00 p.m., Monday through Friday.

Public Notice Date: July 16, 2004  
Permit Number: MO-0112771  
St. Louis Regional Office

<b>FACILITY NAME AND ADDRESS</b>	<b>NAME AND ADDRESS OF OWNER</b>
Bridgeton Landfill Authority 13570 St. Charles Rock Road Bridgeton, MO 63088	Bridgeton Landfill, LLC 13570 St. Charles Rock Road Bridgeton, MO 63088
<b>RECEIVING STREAM &amp; LEGAL DESCRIPTION</b>	<b>TYPE OF DISCHARGE</b>
Unnamed Tributary to Fee Fee Creek (Fee Fee Creek)	Industrial, modification

Outfall #001 - Sec. 34 (projected), T47N, R5E, St. Louis County

Outfall #002 - Eliminated - Sec. 34 (projected), T47N, R5E, St. Louis County

Outfall #003 - Sec. 3 (projected), T46N, R5E, St. Louis County

Outfall #004- Sec. 3 (projected), T46N, R5E, St. Louis County

Outfall #005- Sec. 3 (projected), T46N, R5E, St. Louis County

Outfall #006- Sec. 34 (projected), T47N, R5E, St. Louis County

STATE OF MISSOURI  
**DEPARTMENT OF NATURAL RESOURCES**

MISSOURI CLEAN WATER COMMISSION



**MISSOURI STATE OPERATING PERMIT**

In compliance with the Missouri Clean Water Law, (Chapter 644 R.S. Mo. as amended, hereinafter, the Law), and the Federal Water Pollution Control Act (Public Law 92-500, 92<sup>nd</sup> Congress) as amended,

Permit No. MO-0112771

Owner: Bridgeton Landfill, LLC  
Address: 13570 St. Charles Rock Road, Bridgeton, MO 63088

Continuing Authority: Same as above  
Address: Same as above

Facility Name: Bridgeton Landfill Authority  
Facility Address: 13570 St. Charles Rock Road, Bridgeton, MO 63088

Legal Description: See page 2  
Latitude/Longitude: See page 2

Receiving Stream: Unnamed Tributary to Fee Fee Creek (U)  
First Classified Stream and ID: Fee Fee Creek (P)(01705)  
USGS Basin & Sub-watershed No.: (10300200-180001)

is authorized to discharge from the facility described herein, in accordance with the effluent limitations and monitoring requirements as set forth herein:

**FACILITY DESCRIPTION**

See page 2

This permit authorizes only wastewater discharges under the Missouri Clean Water Law and the National Pollutant Discharge Elimination System; it does not apply to other regulated areas. This permit may be appealed in accordance with Section 644.051.6 of the Law.

Effective Date

Stephen M. Mahfood, Director, Department of Natural Resources  
Executive Secretary, Clean Water Commission

Expiration Date  
MO 780-0041 (10-93)

Mohamad Alhalabi, P.E., Director, St. Louis Regional Office

FACILITY DESCRIPTION (continued)

Outfall #001 - Landfill (Demolition) - SIC #4953

Storm water runoff.

Actual flow is dependent upon precipitation.

Legal Description: SW  $\frac{1}{4}$ , NE  $\frac{1}{4}$ , SW  $\frac{1}{4}$ , Sec. 34 (proj.), T47N, R5E, St. Louis County

Latitude/Longitude: +3846158/-09026373

Outfall #002 - Landfill (Sanitary) - SIC #4953

Eliminated

Legal Description: SE  $\frac{1}{4}$ , NE  $\frac{1}{4}$ , SW  $\frac{1}{4}$ , Sec. 34 (proj.), T47N, R5E, St. Louis County

Latitude/Longitude: +3846136/-09026288

Outfall #003 - Landfill (Sanitary & Demolition)/Concrete Plant - SIC #4953

Storm water runoff/retention basin.

Actual flow is dependent upon precipitation.

Legal Description: SE  $\frac{1}{4}$ , NW  $\frac{1}{4}$ , NE  $\frac{1}{4}$ , Sec. 3 (proj.), T46N, R5E, St. Louis County

Latitude/Longitude: +3845520/-09026534

Outfall #004 - Landfill (Sanitary & Demolition)/Concrete Plant - SIC #4953

Storm water runoff/retention basin.

Actual flow is dependent upon precipitation.

Legal Description: NW  $\frac{1}{4}$ , NE  $\frac{1}{4}$ , Sec. 3 (proj.), T46N, R5E, St. Louis County

Latitude/Longitude: +3846165/-09026313

Outfall #005 - Landfill (Sanitary & Demolition)/Concrete Plant - SIC #4953

Storm water runoff.

Actual flow is dependent upon precipitation.

Legal Description: SE  $\frac{1}{4}$ , NW  $\frac{1}{4}$ , Sec. 3 (proj.), T46N, R5E, St. Louis County

Latitude/Longitude: +3845563/-09027140

Outfall #006 - Landfill (Sanitary & Demolition)/Concrete Plant - SIC #4953

Storm water runoff.

Actual flow is dependent upon precipitation.

Legal Description: SW  $\frac{1}{4}$ , SE  $\frac{1}{4}$ , Sec. 34 (proj.), T47N, R5E, St. Louis County

Latitude/Longitude: +3846320/-09026539

<b>A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS</b>					PAGE NUMBER 3 of 6	
					PERMIT NUMBER MO-0112771	
The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The final effluent limitations shall become effective upon issuance and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below:						
OUTFALL NUMBER AND EFFLUENT PARAMETER(S)	UNITS	FINAL EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS	
		DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
Outfalls #001, #003, #004, #005, #006						
Flow	MGD	*		*	instantaneous once/quarter**	estimate
Rainfall	inches	*		*	daily measurement	***
BETX	mg/L	0.75		0.75	once/quarter**	grab
Biochemical Oxygen Demand <sub>5</sub>	mg/L	60		45	once/quarter**	grab
Chemical Oxygen Demand	mg/L	120		90	once/quarter**	grab
Total Suspended Solids	mg/L	80		60	once/quarter**	grab
Settleable Solids	mL/L/hr	1.5		1.0	once/quarter**	grab
Total Dissolved Solids	mg/L	*		*	once/quarter**	grab
Conductivity (Specific Conductance)	micromhos /cm 25° C	*		*	once/quarter**	grab
Chloride Plus Sulfates	mg/L	1000		*	once/quarter**	grab
Iron, Total Recoverable	mg/L	*		*	once/quarter**	grab
pH - Units	SU	****		****	once/quarter**	grab
MONITORING REPORTS SHALL BE SUBMITTED <u>QUARTERLY</u> ; THE FIRST REPORT IS DUE _____. THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.						
<b>B. STANDARD CONDITIONS</b>						
IN ADDITION TO SPECIFIED CONDITIONS STATED HEREIN, THIS PERMIT IS SUBJECT TO THE ATTACHED <u>Part I</u> STANDARD CONDITIONS DATED <u>October 1, 1980</u> AND HEREBY INCORPORATED AS THOUGH FULLY SET FORTH HEREIN.						

				PAGE NUMBER 4 of 6		
<b>A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS</b>				PERMIT NUMBER MO-0112771		
The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The final effluent limitations shall become effective upon issuance and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below:						
OUTFALL NUMBER AND EFFLUENT PARAMETER(S)	UNITS	FINAL EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS	
		DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
<b><u>Outfalls #001, #003, #004, #005, #006</u></b>						
Calcium	mg/L	*		*	once/year*****	grab
Fluoride	µg/L	*		*	once/year*****	grab
Total Hardness	µg/L	*		*	once/year*****	grab
Barium, Total Recoverable	µg/L	*		*	once/year*****	grab
Boron, Total Recoverable	µg/L	*		*	once/year*****	grab
Cadmium, Total Recoverable	µg/L	*		*	once/year*****	grab
Chromium, Total Recoverable	µg/L	*		*	once/year*****	grab
Cobalt, Total Recoverable	µg/L	*		*	once/year*****	grab
Sodium, Total Recoverable	µg/L	*		*	once/year*****	grab
Ammonia as N	mg/L	*****		*****	once/year*****	grab
Nitrate & Nitrite as N	mg/L	*		*	once/year*****	grab
Phosphorus, Total Recoverable	mg/L	*		*	once/year*****	grab
Mercury, Total Recoverable	µg/L	*		*	once/year*****	grab
Arsenic, Total Recoverable	µg/L	*		*	once/year*****	grab
Lead, Total Recoverable	µg/L	*		*	once/year*****	grab
Selenium, Total Recoverable	µg/L	*		*	once/year*****	grab
Silver, Total Recoverable	µg/L	*		*	once/year*****	grab
Manganese, Total Recoverable	µg/L	*		*	once/year*****	grab
Magnesium, Total Recoverable	µg/L	*		*	once/year*****	grab
Zinc, Total Recoverable	µg/L	*		*	once/year*****	grab
Antimony, Total Recoverable	µg/L	*		*	once/year*****	grab
Beryllium, Total Recoverable	µg/L	*		*	once/year*****	grab
Nickel, Total Recoverable	µg/L	*		*	once/year*****	grab
Sulfate	mg/L	*		*	once/year*****	grab
Thallium, Total Recoverable	µg/L	*		*	once/year*****	grab
Total Organic Carbon	mg/L	*		*	once/year*****	grab
Vanadium, Total Recoverable	µg/L	*		*	once/year*****	grab
Oil & Grease	mg/L	15		10	once/year*****	grab
MONITORING REPORTS SHALL BE SUBMITTED <u>ANNUALLY</u> ; THE FIRST REPORT IS DUE _____. THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.						
<b>B. STANDARD CONDITIONS</b>						
IN ADDITION TO SPECIFIED CONDITIONS STATED HEREIN, THIS PERMIT IS SUBJECT TO THE ATTACHED <u>Part I</u> STANDARD CONDITIONS DATED <u>October 1, 1980</u> AND HEREBY INCORPORATED AS THOUGH FULLY SET FORTH HEREIN.						

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)

- \* Monitoring requirement only.
- \*\* Sample once per quarter in the months of March, May, September & November.
- \*\*\* Grab samples shall be collected during a rainfall event, when there is runoff from the landfill site. The sample shall be collected no later than one hour after runoff begins.
- \*\*\*\* pH is measured in pH units and is not to be averaged. The pH is limited to the range of 6.0-9.0 pH units.
- \*\*\*\*\* The discharge shall not exceed the appropriate values in Table B 10 CSR 20, 7.031.
- \*\*\*\*\* Samples to be taken in September.

C. SPECIAL CONDITIONS

1. This permit may be reopened and modified, or alternatively revoked and reissued, to:
  - (a) Comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a) (2) of the Clean Water Act, if the effluent standard or limitation so issued or approved:
    - (1) contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
    - (2) controls any pollutant not limited in the permit.
  - (b) Incorporate new or modified effluent limitations or other conditions, if the result of a waste load allocation study, toxicity test or other information indicates changes are necessary to assure compliance with Missouri's Water Quality Standards.
  - (c) Incorporate new or modified effluent limitations or other conditions if, as the result of a watershed analysis, a Total Maximum Daily Load (TMDL) limitation is developed for the receiving waters which are currently included in Missouri's list of waters of the state not fully achieving the state's water quality standards, also called the 303(d) list.

The permit as modified or reissued under this paragraph shall also contain any other requirements of the Clean Water Act then applicable.

2. Report as no-discharge when a discharge does not occur during the report period.
3. Changes in Discharges of Toxic Substances

The permittee shall notify the Director as soon as it knows or has reason to believe:

- (a) That any activity has occurred or will occur which would result in the discharge of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels:"
    - (1) One hundred micrograms per liter (100 µg/L);
    - (2) Two hundred micrograms per liter (200 µg/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500 µg/L) for 2,5 dinitrophenol and for 2-methyl-4, 6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony;
    - (3) Five (5) times the maximum concentration value reported for the pollutant in the permit application;
    - (4) The level established in Part A of the permit by the Director.
  - (b) That they have begun or expect to begin to use or manufacture as an intermediate or final product or byproduct any toxic pollutant, which was not reported in the permit application.
4. All design and operating specifications and all Waste Management Program approval conditions pertaining to water quality are hereby made a part of this permit and shall apply throughout the life of this permit without regard to other conditions, permits, occurrences, etc.

C. SPECIAL CONDITIONS (continued)

5. This permit does not allow the discharge of storm water that has contacted the open face of the landfill. This permit does not allow the discharge of untreated leachate. All leachate shall be handled in accordance with the Solid Waste Disposal Area Operating Permit, Report of Approval of Plans and Specifications (with conditions).
6. All discharges shall comply with the Missouri Water Quality Standards, 10 CSR 20, 7.031, Section (3)(C), which states "Waters shall be free from substance in sufficient amounts to cause unsightly color or turbidity..", and Section (4)(G), which states "Water contaminants shall not cause or contribute to turbidity or color that will cause substantial visible contact with the natural appearance of the stream...".
7. All activities performed to control erosion on the landfill site (seeding, mulching, terracing, etc.) shall be described and submitted along with the second quarter and fourth quarter Discharge Monitoring Reports. If no erosion controls are undertaken, indicate so on the reports.
8. Provide sediment and erosion control sufficient to prevent or control pollution of storm water runoff.
9. If truck emptying or dumping and washing concrete materials is done on site, provide sediment control for dumping of residual concrete and washdown waters in such a way as to meet the limitations of this permit. A construction permit would need to be obtained from the department before beginning construction of treatment structures. Concrete or untreated washdown water shall not be introduced directly into waters of the state.
10. Prevent the spillage or loss of fluids, oil, grease, gasoline, etc. from vehicle and equipment maintenance and repair activities and thereby prevent the contamination of storm water from these substances.
11. All fueling facilities present on the site shall adhere to applicable federal and state regulations concerning underground storage, above ground storage, and dispensers, including spill prevention, control and counter measures.
12. Store all paint, paint solvent, petroleum products and petroleum waste products (except fuels), and storage containers (such as drums, cans, or cartons) so that these materials are not exposed to the storm water. Provide spill prevention, control, and/or management sufficient to prevent any spills of these pollutants from entering a water of the state. Any containment system used to implement this requirement shall be constructed of materials compatible with the substances contained and shall also prevent the contamination of groundwater.